



Overview



14225 SW Tualatin Valley H
Beaverton, OR 97005
tel: (888) 642-2410
www.techsafety.com

Single Pass Certification Report

Cert.: KM186181197 Facility: Wilson's Compounding Pharmacy ID: 418340 Cust ID: NA
SO: OR-WLS18002B-1 Addr: 3925 Columbia Rd Make: ACME
Contact: Jane Wilson St Louis, MO 63124 Model: POWDER BOOTH
Phone: (314) 321-2522 Bid: Main SN: 11111111
Email: jane_wilson@yahoo.com Rm: Mix Lab Class: I Type: Single Pass

Test Standard(s): MANUFACTURER, IEST-RP-CC034.4

Results

Inspected	Min	Max	Measured	Results
Average Inflow Velocity (FPM)	75	NA	77	Pass
Minimum Point Reading (FPM)	NA	NA	64	NA
Airflow Smoke Pattern	NA	NA	Pass	Pass
Lighting Fluorescent (FC)	NA	NA	NA	FIO
Lighting Ultraviolet (uW/cm2)	NA	NA	NA	FIO
Unit Duct Pressure (In.W.C.)	NA	NA	NA	FIO
Unit Supply Pressure (In.W.C.)	NA	NA	0.13	FIO
Airflow Monitor	NA	NA	No	FIO
Saturation Monitor	NA	NA	No	FIO

Exhaust	Min	Max	Measured	Results
HEPA As Found Max Point Leak (%)	0.000	0.010	0.000	Pass
HEPA As Left Max Point Leak (%)	0.000	0.010	NA	NA
Patch (%)	0	3	Pre:0/New:0/Tot:0	Pass
Aerosol Concentration (ug/l)	10	100	83	FIO

Comments: Unit is vented back in the room and exhaust filter could be scanned (no ductwork)

This unit does not have an airflow monitor, so the suggested testing interval is every 6 months.

The lower inflow readings in the middle of the access area are likely due to the balance located just inside the unit. Smoke is still contained in the unit, so relocation of the balance should not be necessary.

This certificate is a sample.

**** Unit Certified ****

The following NIST-Traceable equipment were used to perform this test:

Equipment ID	Equipment Type	Serial #	Calibration Due Date
001425	Photometer	9493	01/29/2019
004050	Generator	EQ4050	12/26/2018
004262	Anemometer	T95351705011	02/21/2019

Report Date: 06/18/2018

Retest Date: 12/18/2018

eData: v6.5.4

Print Version: Service Manager v6.5.4

Print Date: 06/18/2018 Page: 1/2

FIO: For Information Only NA: Not Applicable

Los Angeles
San Diego
Washington
Oregon
Colorado

Berkeley

Connecticut
Maryland
Massachusetts
New Jersey
New York

www.techsafety.com

Kyle Mulder
Field Service Technician - Level 4
06/18/2018 11:15 AM
I certify that this record is a true and accurate representation of work performed.



Overview



14225 SW Tualatin Valley H
Beaverton, OR 97005
tel: (888) 642-2410
www.techsafety.com

Single Pass Certification Report

Cert.: KM186181197 Facility: Wilson's Compounding Pharmacy ID: 418340 Cust ID: NA
SO: OR-WLS18002B-1 Addr: 3925 Columbia Rd Make: ACME
Contact: Jane Wilson St Louis, MO 63124 Model: POWDER BOOTH
Phone: (314) 321-2522 Bid: Main SN: 11111111
Email: jane_wilson@yahoo.com Rm: Mix Lab Class: I Type: Single Pass

Inflow (FPM)

Dimension (inches): Width: 47 Height: 9

Average Inflow Velocity(FPM): 77

Area (sq.ft.): 2.94


Volume (CFM): 226

Readings:

86	64	71	88
----	----	----	----

Report Date: 06/18/2018
Retest Date: 12/18/2018
eData: v6.5.4
Print Version: Service Manager v6.5.4
Print Date: 06/18/2018 Page: 2/2
FIO: For Information Only NA: Not Applicable

Los Angeles
San Diego
Washington
Oregon
Colorado
Berkeley
Connecticut
Maryland
Massachusetts
New Jersey
New York
www.techsafety.com


Kyle Mulder 06/18/2018 11:15 AM
Field Service Technician - Level 4
I certify that this record is a true and accurate
representation of work performed.



Content Details

Unit/Report Type

Single Pass Certification Report

Cert.: KM186181197	Facility: Wilson's Compounding Pharmacy	ID: 418340	Cust ID: NA
SO: OR-WLS18002B-1	Addr: 3925 Columbia Rd	Make: ACME	
Contact: Jane Wilson	St Louis, MO 63124	Model: POWDER BOOTH	
Phone: (314) 321-2522	Bld: Main	SN: 11111111	
Email: jane_wilson@yahoo.com	Rm: Mix Lab	Class: I	Type: Single Pass

Test Standard(s): MANUFACTURER, IEST-RP-CC034.4

Applicable Test Standards relevant to the certification of this device.

Unit Information Including:

- Certificate ID # ("Cert.")
- Service Order Reference # (SO)
- [Primary] Project Contact Info
- Unit Location Information (Address, Building, Room)
- Unit Information (Make, Model, Serial Number, Hood Type)

Content Details

Average Inflow Velocity: Average of all velocity measurements taken across the HEPA filter in feet per minute (fpm).

Minimum Point Reading: The lowest velocity reading measured from set of velocity data in feet per minute (fpm)

Using an aerosol-generating source, the technician observes the movement of tracer. Tracer should not escape unit after entering.

		Results			
Inspected		Min	Max	Measured	Results
Average Inflow Velocity (FPM)		75	NA	77	Pass
Minimum Point Reading (FPM)		NA	NA	64	NA
Airflow Smoke Pattern		NA	NA	Pass	Pass
Lighting Fluorescent (FC)		NA	NA	NA	FIO
Lighting Ultraviolet (uW/cm2)		NA	NA	NA	FIO
Unit Duct Pressure (In.W.C.)		NA	NA	NA	FIO
Unit Supply Pressure (In.W.C.)		NA	NA	0.13	FIO
Airflow Monitor		NA	NA	No	FIO
Saturation Monitor		NA	NA	No	FIO

Duct Pressure: Pressure measurement from the exhaust duct to ambient.

Supply Pressure: Across the HEPA filter from upstream to downstream.

Light intensity measurement results whenever applicable. Not necessary for certification.

Content Details

Airflow and **Saturation** monitor *presence* confirmation tests. The technical confirms whether an [inflow] Airflow or a [chemical] saturation monitor is present.

	Airflow Monitor	NA	NA	No	FIO
	Saturation Monitor	NA	NA	No	FIO
Exhaust		Min	Max	Measured	Results
	HEPA As Found Max Point Leak (%)	0.000	0.010	0.000	Pass
	HEPA As Left Max Point Leak (%)	0.000	0.010	NA	NA
	Patch (%)	0	3	Pre:0/New:0/Tot:0	Pass
	Aerosol Concentration (ug/l)	10	100	83	FIO

HEPA As-Found/Left Max Leak (%): Aerosol concentration detected downstream of filter expressed as a ratio (%) against the upstream concentration.

Patch (%): Amount of patch (silicone) present on filter expressed as a ration against the filter surface area. "New" patching is added typically when leaks are detected.

Aerosol Concentration: Concentration of aerosol introduced upstream for the leak test.

Content Details

Technician comments that elaborate on the results of the testing or describe observations beyond the results listed in the certificate.

Comments: Unit is vented back in the room and exhaust filter could be scanned (no ductwork)

This unit does not have an airflow monitor, so the suggested testing interval is every 6 months.

The lower inflow readings in the middle of the access area are likely due to the balance located just inside the unit. Smoke is still contained in the unit, so relocation of the balance should not be necessary.

This certificate is a sample.

***** Unit Certified *****

The following NIST-Traceable equipment were used to perform this test:

Equipment ID	Equipment Type	Serial #	Calibration Due Date
001425	Photometer	9493	01/29/2019
004050	Generator	EQ4050	12/26/2018
004262	Anemometer	T95351705011	02/21/2019

Equipment list used to generate the data in this certificate.

The certification status of the unit upon evaluation against applicable criteria.

Content Details

Report Date: 06/18/2018
Retest Date: 12/18/2018
eData: v6.5.4
Print Version: Service Manager v6.5.4
Print Date: 06/18/2018 Page: 1/2
FIO: For Information Only NA: Not Applicable


Los Angeles
San Diego
Washington
Oregon
Colorado

Berkeley

Connecticut
Maryland
Massachusetts
New Jersey
New York


www.techsafety.com


Technician's "digital ink" signature.


Kyle Mulder 06/18/2018 11:15 AM
Field Service Technician - Level 4
I certify that this record is a true and accurate
representation of work performed.

Report Date = Date certificate was created.
Retest Date = (Relative) Due date of unit.
Print Date = Date this *manifestation* of unit
certificate was created. (Certification Date is
always same upon completion in the field!)

Technician's "CFR Part 11" Compliant signature.

Content Details





TSS – National Headquarters
620 Hearst Avenue
Berkeley, California 94710
510.845.5591
800.877.7742
www.techsafety.com